



Wood for Zero.

NERO – Cost reduction of new Nearly-Zero Energy Wooden buildings in Northern Climate Conditions

D1.4. Online energy monitoring functionality definition

Authors:

Jarek Kurnitski, Kaiser Ahmed



This project has received funding from the European Union's Horizon 2020 research and innovation programme under grant agreement No 754177

D1.4	Online energy monitoring functionality definition		
Project :	NERO H2020- 754 177	Start / Duration:	1 September 2017 / 36 Months
Dissemination¹:	PU	Nature²:	R
Due Date :	M6		
Filename³:	D1.4_ Online energy monitoring functionality definition.doc ³		

ABSTRACT:

In this document the online system monitoring functionality requirements are defined for the energy use, indoor temperature and indoor air quality.

Deliverable Contributors:	Name	Organisation	Role / Title
Deliverable Leader ⁴	Jarek Kurnitski	Aalto university	Professor
Contributing Author(s) ⁵	Jarek Kurnitski	Aalto university	Professor
	Kaiser Ahmed	Aalto university	Doctoral candidate
Reviewer(s) ⁶	Consortium partners		
Final review and approval	Tero Hasu	Kouvola Innovation	Coordinator

¹ PU = Public; CO = Confidential, only for members of the Consortium (including the EC services).

² R = Report; R+O = Report plus Other. Note: all "O" deliverables must be accompanied by a deliverable report.

³ eg DX.Y_name to the deliverable_v0xx. v1 corresponds to the final release submitted to the EC.

⁴ Person from the lead beneficiary that is responsible for the deliverable.

⁵ Person(s) from contributing partners for the deliverable.

⁶ Typically person(s) with appropriate expertise to assess the deliverable quality.

Disclaimer

The work and research leading to these results has received funding from the European Union's Horizon 2020 Research and Innovation programme under grant agreement no 754 177.

This document contains findings, work and products of the NERO project. Certain parts of it might be under partner Intellectual Property Right (IPR) rules so, prior to using its content please contact the consortium head for approval.

The authors of this document have taken any available measure in order for its content to be accurate, consistent and lawful. However, neither the project consortium as a whole nor the individual partners that implicitly or explicitly participated in the creation and publication of this document hold any sort of responsibility that might occur as a result of using its content.

Table of Contents

Online energy monitoring minimum functionality definition.....	5
1. Energy data with multiple segments	5
2. Indoor temperature and CO ₂ data.....	5

Online energy monitoring minimum functionality definition

1. Energy data with multiple segments

The energy use data needs to visualize in user interface of onsite computer and can be accessible in web. Data should show the main energy uses, onsite generation, exported, delivered energy, and common technical system level data, i.e. AHU, plant details.

2. Indoor temperature and CO₂ data

Indoor temperature and CO₂ data for each representative room during occupied and non-occupied hour needs to be available in user interface of onsite computer and web. Summary of information to be monitored by BMS is shown in Table 1.

Table 1. Presented building information in web or onsite computer.

Energy data	Unit
Onsite production	kWh/m ² a
Exported energy	kWh/m ² a
Energy use of main services	
Heating	kWh/m ² a
Cooling	kWh/m ² a
DHW	kWh/m ² a
Fans and pumps	kWh/m ² a
Appliance	kWh/m ² a
Lighting	kWh/m ² a
Indoor climate data for representative rooms (3-5 rooms or more)	
Room temperature	°C
CO ₂	ppm
Air handling unit	
Temperatures before and after main components	°C
CO ₂ level at extract air	ppm
Pressure rise and filter pressure drop	Pa
Heat recovery efficiency	%
Fan and pump speeds	%
Plant details	
Supply water temperature	°C
Return water temperature	°C
Heat capacity	kW